

RC GROUP Technical Documentation  
NRCS-FC-Z\_0152\_1604\_201802\_ML

# REGULATION (EU) N. 2016/2281 FOR HIGH TEMPERATURE PROCESS CHILLERS

Ecodesign requirements for process chillers

AIR COOLED CHILLERS - FREECOOLING

**NRCS-FC-Z 0152 - 1604**

Cooling Capacity Range 35,9 - 424 [kW] - (EN14511 VALUE)  
Nominal Cooling Capacity at TdesignC Range 35,9 - 424 [kW]



IT

EN

DE

ES

FR

<b>1. REGULATION (EU) N. 2016/2281 FOR HIGH TEMPERATURE PROCESS CHILLERS</b>	
1.1 Scope of the document	3
1.2 REGULATION (UE) N. 2016/2281 description	3
1.3 Description of the data declared by Mitsubishi Electric Hydronics & IT Cooling Systems	3
<b>2. RC GROUP CONTENTS UNIT</b>	
2.1 Table index	4
<b>3. TECHNICAL PARAMETERS</b>	
3.1 NRCS-FC-Z /B	5
3.2 NRCS-FC-Z /SL	42



# 1. REGULATION (EU) N. 2016/2281 FOR HIGH TEMPERATURE PROCESS CHILLERS

## 1.1 Scope of the document

This document is compliant with the Commission Regulation (EU) N. 2016/2281 regarding "REQUIREMENTS FOR PRODUCT INFORMATION" (Annex II, Point 5). In particular, it deals with high temperature process chillers and contains information required by Table 15 of the above-mentioned regulation, which is entitled "Information requirements for high temperature process chillers".

## 1.2 REGULATION (UE) N. 2016/2281 description

The COMMISSION REGULATION (EU) N. 2016/2281 of 30 November 2016, implementing Directive 2009/125/EC of the European Parliament and of the Council, establishes eco-design requirements for the placing on the market and/or putting into service of: air heating products with a rated heating capacity which does not exceed 1MW, cooling products and high temperature process chillers with a rated cooling capacity which do not exceed 2 MW, and all fan coil units. All these energy-related products are defined in Article 2 of the Regulation in question.

## 1.3 Description of the data declared by Mitsubishi Electric Hydronics & IT Cooling Systems

- High temperature process chiller: a product designed to cool down and continuously maintain the temperature of a liquid to provide cooling to a refrigerated appliance or system, whose aim is not to provide cooling for the thermal comfort of human beings. It is capable of delivering its rated refrigeration capacity at an indoor side heat exchanger outlet temperature of 7°C, at standard rating conditions.
- Rated refrigeration capacity (P): the refrigeration capacity that the high temperature process chiller is able to reach when operating at full load at a specific rating point, expressed in kW.
- Seasonal Energy Performance Ratio (SEPR): the efficiency ratio of a high temperature process chiller at standard rating conditions, representative of the variations in load and ambient temperature throughout the year, and calculated as the ratio between the annual refrigeration demand and the annual electricity consumption.
- Annual electricity consumption: result of the sum of the ratios between each bin-specific cooling demand and the corresponding bin-specific energy efficiency ratio, multiplied by the corresponding number of bin hours.
- Degradation coefficient for chillers: measure of efficiency loss due to cycling of the chiller.
- Capacity control: the ability of a chiller to change its cooling capacity by changing the volumetric flow rate of at least one of the fluids needed to operate the refrigeration cycle.
- Global warming potential (GWP) of the refrigerant: the 100-year climatic warming potential of one kilogram of a greenhouse gas relative to one kilogram of dioxide (CO<sub>2</sub>).

## 2. RC GROUP CONTENTS UNIT

### 2.1 Table index

AIR COOLED CHILLERS - FREECOOLING

#### NRCS-FC-Z 0152 - 1604

Cooling Capacity Range 35,9 - 424 [kW]

Nominal Cooling Capacity at TdesignC Range 35,9 - 424 [kW]

Units	Version	Size					Pag.
NRCS-FC-Z	B	0152	0152	0182	0182	0202	5
		0252	0302	0302	0352	0352	
		0412	0412	0452	0452	0512	
		0512	0552	0552	0604	0604	
		0612	0612	0704	0704	0804	
		0804	0904	0904	1004	1004	
		1104	1104	1204	1204	1404	
		1404	1604				
NRCS-FC-Z	SL	0152	0152	0182	0182	0202	42
		0202	0252	0252	0302	0302	
		0352	0352	0412	0412	0452	
		0452	0512	0512	0552	0552	
		0604	0604	0612	0612	0704	
		0704	0804	0804	0904	0904	
		1004	1004	1104	1104	1204	
		1204	1404	1404	1604	1604	

NRCS-FC-Z /NG /B 0152			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,83
Annual electricity consumption	Q	[kWh]	58270
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	38,00
Rated power input	D <sub>A</sub>	[kW]	15,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,44
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	35,47
Rated power input	D <sub>B</sub>	[kW]	10,20
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,48
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	32,93
Rated power input	D <sub>C</sub>	[kW]	7,08
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,65
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	26,70
Rated power input	D <sub>D</sub>	[kW]	5,18
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,16
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0152			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,57
Annual electricity consumption	Q	[kWh]	50723
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	38,10
Rated power input	D <sub>A</sub>	[kW]	15,40
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,47
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	35,56
Rated power input	D <sub>B</sub>	[kW]	10,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,56
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	33,02
Rated power input	D <sub>C</sub>	[kW]	6,95
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,75
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	26,80
Rated power input	D <sub>D</sub>	[kW]	5,11
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,24
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 0182			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,28
Annual electricity consumption	Q	[kWh]	63290
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	45,07
Rated power input	D <sub>A</sub>	[kW]	17,00
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,66
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	42,09
Rated power input	D <sub>B</sub>	[kW]	11,30
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,73
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	39,09
Rated power input	D <sub>C</sub>	[kW]	7,78
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,03
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	31,70
Rated power input	D <sub>D</sub>	[kW]	5,65
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,60
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0182			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		6,01
Annual electricity consumption	Q	[kWh]	55690
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	45,20
Rated power input	D <sub>A</sub>	[kW]	16,80
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,69
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	42,19
Rated power input	D <sub>B</sub>	[kW]	11,20
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,77
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	39,17
Rated power input	D <sub>C</sub>	[kW]	7,65
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,12
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	31,80
Rated power input	D <sub>D</sub>	[kW]	5,57
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,70
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy



NRCS-FC-Z / B 0202			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,64
Annual electricity consumption	Q	[kWh]	87120
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	54,55
Rated power input	D <sub>A</sub>	[kW]	21,20
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,58
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	50,96
Rated power input	D <sub>B</sub>	[kW]	14,90
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,42
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	47,32
Rated power input	D <sub>C</sub>	[kW]	11,40
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,15
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	36,50
Rated power input	D <sub>D</sub>	[kW]	8,13
Declared energy efficiency ratio	EER <sub>DC,D</sub>		4,48
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0252			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,57
Annual electricity consumption	Q	[kWh]	97424
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	59,80
Rated power input	D <sub>A</sub>	[kW]	24,30
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,46
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	55,81
Rated power input	D <sub>B</sub>	[kW]	17,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,28
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	51,83
Rated power input	D <sub>C</sub>	[kW]	12,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,05
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	40,80
Rated power input	D <sub>D</sub>	[kW]	9,23
Declared energy efficiency ratio	EER <sub>DC,D</sub>		4,42
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 0302			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,58
Annual electricity consumption	Q	[kWh]	126408
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	78,10
Rated power input	D <sub>A</sub>	[kW]	30,90
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,53
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	72,89
Rated power input	D <sub>B</sub>	[kW]	21,20
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,44
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	67,69
Rated power input	D <sub>C</sub>	[kW]	15,90
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,26
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	53,00
Rated power input	D <sub>D</sub>	[kW]	11,40
Declared energy efficiency ratio	EER <sub>DC,D</sub>		4,66
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0302			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,92
Annual electricity consumption	Q	[kWh]	117895
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	78,25
Rated power input	D <sub>A</sub>	[kW]	30,80
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,54
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	73,08
Rated power input	D <sub>B</sub>	[kW]	21,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,48
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	67,86
Rated power input	D <sub>C</sub>	[kW]	15,70
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,32
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	53,10
Rated power input	D <sub>D</sub>	[kW]	11,30
Declared energy efficiency ratio	EER <sub>DC,D</sub>		4,68
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 0352			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,97
Annual electricity consumption	Q	[kWh]	137051
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	92,00
Rated power input	D <sub>A</sub>	[kW]	33,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,74
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	85,87
Rated power input	D <sub>B</sub>	[kW]	23,40
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,67
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	79,73
Rated power input	D <sub>C</sub>	[kW]	17,50
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,55
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	54,40
Rated power input	D <sub>D</sub>	[kW]	11,20
Declared energy efficiency ratio	EER <sub>DC,D</sub>		4,87
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0352			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,41
Annual electricity consumption	Q	[kWh]	126167
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	92,20
Rated power input	D <sub>A</sub>	[kW]	33,40
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,76
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	86,05
Rated power input	D <sub>B</sub>	[kW]	23,20
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,71
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	79,91
Rated power input	D <sub>C</sub>	[kW]	17,30
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,62
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	54,40
Rated power input	D <sub>D</sub>	[kW]	11,20
Declared energy efficiency ratio	EER <sub>DC,D</sub>		4,86
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 0412			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,00
Annual electricity consumption	Q	[kWh]	149945
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	101,20
Rated power input	D <sub>A</sub>	[kW]	38,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,62
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	94,45
Rated power input	D <sub>B</sub>	[kW]	26,20
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,61
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	87,71
Rated power input	D <sub>C</sub>	[kW]	18,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,66
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	72,10
Rated power input	D <sub>D</sub>	[kW]	14,00
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,16
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0412			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,42
Annual electricity consumption	Q	[kWh]	138519
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	101,40
Rated power input	D <sub>A</sub>	[kW]	38,40
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,64
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	94,64
Rated power input	D <sub>B</sub>	[kW]	25,90
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,65
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	87,88
Rated power input	D <sub>C</sub>	[kW]	18,60
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,73
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	72,20
Rated power input	D <sub>D</sub>	[kW]	13,90
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,19
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy



NRCS-FC-Z /NG /B 0452			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,73
Annual electricity consumption	Q	[kWh]	181429
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	115,67
Rated power input	D <sub>A</sub>	[kW]	44,30
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,61
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	107,99
Rated power input	D <sub>B</sub>	[kW]	31,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,48
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	100,27
Rated power input	D <sub>C</sub>	[kW]	23,10
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,34
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	73,70
Rated power input	D <sub>D</sub>	[kW]	15,50
Declared energy efficiency ratio	EER <sub>DC,D</sub>		4,74
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0452			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,05
Annual electricity consumption	Q	[kWh]	170122
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	$P_A$	[kW]	115,87
Rated power input	$D_A$	[kW]	44,10
Rated energy efficiency ratio	$EER_{DC,A}$		2,63
Parameters at rating point B			
Rated refrigeration capacity	$P_B$	[kW]	108,17
Rated power input	$D_B$	[kW]	30,80
Declared energy efficiency ratio	$EER_{DC,B}$		3,51
Parameters at rating point C			
Rated refrigeration capacity	$P_C$	[kW]	100,45
Rated power input	$D_C$	[kW]	22,90
Declared energy efficiency ratio	$EER_{DC,C}$		4,38
Parameters at rating point D			
Rated refrigeration capacity	$P_D$	[kW]	73,70
Rated power input	$D_D$	[kW]	15,50
Declared energy efficiency ratio	$EER_{DC,D}$		4,76
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	$C_{DC}$		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 0512			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,97
Annual electricity consumption	Q	[kWh]	196483
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	131,70
Rated power input	D <sub>A</sub>	[kW]	47,40
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,78
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	122,92
Rated power input	D <sub>B</sub>	[kW]	33,10
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,71
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	114,14
Rated power input	D <sub>C</sub>	[kW]	24,60
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,64
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	90,10
Rated power input	D <sub>D</sub>	[kW]	17,80
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,06
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0512			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,38
Annual electricity consumption	Q	[kWh]	181714
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	131,88
Rated power input	D <sub>A</sub>	[kW]	47,10
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,80
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	123,11
Rated power input	D <sub>B</sub>	[kW]	32,90
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,74
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	114,31
Rated power input	D <sub>C</sub>	[kW]	24,40
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,68
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	90,00
Rated power input	D <sub>D</sub>	[kW]	17,90
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,03
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 0552			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,07
Annual electricity consumption	Q	[kWh]	214413
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	146,80
Rated power input	D <sub>A</sub>	[kW]	55,40
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,65
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	137,01
Rated power input	D <sub>B</sub>	[kW]	38,20
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,59
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	127,23
Rated power input	D <sub>C</sub>	[kW]	27,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,58
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	91,30
Rated power input	D <sub>D</sub>	[kW]	17,90
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,11
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0552			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,39
Annual electricity consumption	Q	[kWh]	202093
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	147,00
Rated power input	D <sub>A</sub>	[kW]	55,30
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,66
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	137,20
Rated power input	D <sub>B</sub>	[kW]	38,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,61
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	127,40
Rated power input	D <sub>C</sub>	[kW]	27,60
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,62
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	91,40
Rated power input	D <sub>D</sub>	[kW]	17,80
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,13
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0604			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,27
Annual electricity consumption	Q	[kWh]	220732
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	156,89
Rated power input	D <sub>A</sub>	[kW]	61,30
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,56
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	146,44
Rated power input	D <sub>B</sub>	[kW]	39,90
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,67
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	135,98
Rated power input	D <sub>C</sub>	[kW]	30,20
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,50
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	125,52
Rated power input	D <sub>D</sub>	[kW]	17,25
Declared energy efficiency ratio	EER <sub>DC,D</sub>		7,28
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 0604			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,87
Annual electricity consumption	Q	[kWh]	238219
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	156,65
Rated power input	D <sub>A</sub>	[kW]	61,50
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,55
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	146,25
Rated power input	D <sub>B</sub>	[kW]	40,10
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,65
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	135,81
Rated power input	D <sub>C</sub>	[kW]	30,40
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,47
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	125,36
Rated power input	D <sub>D</sub>	[kW]	20,76
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,04
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy



NRCS-FC-Z /NG /B 0612			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,78
Annual electricity consumption	Q	[kWh]	255859
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	165,00
Rated power input	D <sub>A</sub>	[kW]	64,20
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,57
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	154,00
Rated power input	D <sub>B</sub>	[kW]	44,10
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,49
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	143,00
Rated power input	D <sub>C</sub>	[kW]	32,10
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,45
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	116,10
Rated power input	D <sub>D</sub>	[kW]	23,50
Declared energy efficiency ratio	EER <sub>DC,D</sub>		4,95
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0612			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,08
Annual electricity consumption	Q	[kWh]	240949
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	165,10
Rated power input	D <sub>A</sub>	[kW]	64,00
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,58
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	154,09
Rated power input	D <sub>B</sub>	[kW]	44,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,50
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	143,09
Rated power input	D <sub>C</sub>	[kW]	32,00
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,47
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	116,10
Rated power input	D <sub>D</sub>	[kW]	23,50
Declared energy efficiency ratio	EER <sub>DC,D</sub>		4,93
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0704			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,48
Annual electricity consumption	Q	[kWh]	247138
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	182,70
Rated power input	D <sub>A</sub>	[kW]	67,70
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,70
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	170,52
Rated power input	D <sub>B</sub>	[kW]	44,70
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,81
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	158,34
Rated power input	D <sub>C</sub>	[kW]	33,30
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,75
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	146,16
Rated power input	D <sub>D</sub>	[kW]	19,63
Declared energy efficiency ratio	EER <sub>DC,D</sub>		7,45
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 0704			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,13
Annual electricity consumption	Q	[kWh]	263515
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	182,47
Rated power input	D <sub>A</sub>	[kW]	68,10
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,68
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	170,33
Rated power input	D <sub>B</sub>	[kW]	44,90
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,79
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	158,17
Rated power input	D <sub>C</sub>	[kW]	33,50
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,72
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	146,00
Rated power input	D <sub>D</sub>	[kW]	22,91
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,37
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0804			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,97
Annual electricity consumption	Q	[kWh]	308138
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	206,60
Rated power input	D <sub>A</sub>	[kW]	79,50
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,60
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	192,83
Rated power input	D <sub>B</sub>	[kW]	53,40
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,61
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	179,05
Rated power input	D <sub>C</sub>	[kW]	40,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,39
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	165,28
Rated power input	D <sub>D</sub>	[kW]	25,53
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,48
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 0804			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,66
Annual electricity consumption	Q	[kWh]	328042
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	206,36
Rated power input	D <sub>A</sub>	[kW]	79,70
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,59
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	192,64
Rated power input	D <sub>B</sub>	[kW]	53,60
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,59
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	178,88
Rated power input	D <sub>C</sub>	[kW]	41,00
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,36
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	165,12
Rated power input	D <sub>D</sub>	[kW]	29,62
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,57
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 0904			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,45
Annual electricity consumption	Q	[kWh]	321641
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	236,70
Rated power input	D <sub>A</sub>	[kW]	86,10
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,75
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	220,92
Rated power input	D <sub>B</sub>	[kW]	58,30
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,79
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	205,14
Rated power input	D <sub>C</sub>	[kW]	44,00
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,66
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	189,36
Rated power input	D <sub>D</sub>	[kW]	25,15
Declared energy efficiency ratio	EER <sub>DC,D</sub>		7,53
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 0904			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,04
Annual electricity consumption	Q	[kWh]	347640
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	236,30
Rated power input	D <sub>A</sub>	[kW]	86,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,73
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	220,55
Rated power input	D <sub>B</sub>	[kW]	58,70
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,76
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	204,79
Rated power input	D <sub>C</sub>	[kW]	44,40
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,61
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	189,04
Rated power input	D <sub>D</sub>	[kW]	30,25
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,25
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy



NRCS-FC-Z / B 1004			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,47
Annual electricity consumption	Q	[kWh]	350795
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	259,20
Rated power input	D <sub>A</sub>	[kW]	96,40
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,69
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	241,92
Rated power input	D <sub>B</sub>	[kW]	63,60
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,80
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	224,64
Rated power input	D <sub>C</sub>	[kW]	47,70
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,71
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	207,36
Rated power input	D <sub>D</sub>	[kW]	27,56
Declared energy efficiency ratio	EER <sub>DC,D</sub>		7,53
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 1004			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,09
Annual electricity consumption	Q	[kWh]	376387
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	258,80
Rated power input	D <sub>A</sub>	[kW]	96,90
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,67
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	241,55
Rated power input	D <sub>B</sub>	[kW]	64,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,77
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	224,29
Rated power input	D <sub>C</sub>	[kW]	48,10
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,66
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	207,04
Rated power input	D <sub>D</sub>	[kW]	32,58
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,35
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 1104			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,72
Annual electricity consumption	Q	[kWh]	384525
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	296,90
Rated power input	D <sub>A</sub>	[kW]	109,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,71
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	277,11
Rated power input	D <sub>B</sub>	[kW]	71,80
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,86
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	257,31
Rated power input	D <sub>C</sub>	[kW]	52,70
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,88
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	237,52
Rated power input	D <sub>D</sub>	[kW]	29,45
Declared energy efficiency ratio	EER <sub>DC,D</sub>		8,06
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 1104			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,21
Annual electricity consumption	Q	[kWh]	422157
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	296,56
Rated power input	D <sub>A</sub>	[kW]	109,90
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,70
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	276,83
Rated power input	D <sub>B</sub>	[kW]	72,10
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,84
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	257,05
Rated power input	D <sub>C</sub>	[kW]	53,00
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,85
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	237,28
Rated power input	D <sub>D</sub>	[kW]	37,12
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,39
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 1204			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,34
Annual electricity consumption	Q	[kWh]	462225
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	332,90
Rated power input	D <sub>A</sub>	[kW]	127,10
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,62
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	310,71
Rated power input	D <sub>B</sub>	[kW]	83,60
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,72
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	288,51
Rated power input	D <sub>C</sub>	[kW]	62,40
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,62
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	266,32
Rated power input	D <sub>D</sub>	[kW]	36,63
Declared energy efficiency ratio	EER <sub>DC,D</sub>		7,27
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 1204			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,92
Annual electricity consumption	Q	[kWh]	501045
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	332,50
Rated power input	D <sub>A</sub>	[kW]	127,40
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,61
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	310,33
Rated power input	D <sub>B</sub>	[kW]	84,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,69
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	288,17
Rated power input	D <sub>C</sub>	[kW]	62,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,59
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	266,00
Rated power input	D <sub>D</sub>	[kW]	44,53
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,97
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z / B 1404			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,68
Annual electricity consumption	Q	[kWh]	497522
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	$P_A$	[kW]	381,50
Rated power input	$D_A$	[kW]	139,70
Rated energy efficiency ratio	$EER_{DC,A}$		2,73
Parameters at rating point B			
Rated refrigeration capacity	$P_B$	[kW]	356,07
Rated power input	$D_B$	[kW]	92,80
Declared energy efficiency ratio	$EER_{DC,B}$		3,84
Parameters at rating point C			
Rated refrigeration capacity	$P_C$	[kW]	330,63
Rated power input	$D_C$	[kW]	68,90
Declared energy efficiency ratio	$EER_{DC,C}$		4,80
Parameters at rating point D			
Rated refrigeration capacity	$P_D$	[kW]	305,20
Rated power input	$D_D$	[kW]	37,73
Declared energy efficiency ratio	$EER_{DC,D}$		8,09
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	$C_{DC}$		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /B 1404			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,19
Annual electricity consumption	Q	[kWh]	542984
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	380,60
Rated power input	D <sub>A</sub>	[kW]	141,00
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,70
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	355,23
Rated power input	D <sub>B</sub>	[kW]	93,70
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,79
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	329,85
Rated power input	D <sub>C</sub>	[kW]	69,90
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,72
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	304,48
Rated power input	D <sub>D</sub>	[kW]	46,35
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,57
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy



NRCS-FC-Z / B 1604			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,17
Annual electricity consumption	Q	[kWh]	607822
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	423,96
Rated power input	D <sub>A</sub>	[kW]	160,00
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,65
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	395,73
Rated power input	D <sub>B</sub>	[kW]	106,90
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,70
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	367,47
Rated power input	D <sub>C</sub>	[kW]	83,30
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,41
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	339,20
Rated power input	D <sub>D</sub>	[kW]	48,19
Declared energy efficiency ratio	EER <sub>DC,D</sub>		7,04
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0152			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,19
Annual electricity consumption	Q	[kWh]	51271
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	35,90
Rated power input	D <sub>A</sub>	[kW]	15,70
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,28
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	33,51
Rated power input	D <sub>B</sub>	[kW]	9,44
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,55
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	31,11
Rated power input	D <sub>C</sub>	[kW]	6,09
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,11
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	26,40
Rated power input	D <sub>D</sub>	[kW]	4,63
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,71
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0152			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		6,03
Annual electricity consumption	Q	[kWh]	44373
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	36,06
Rated power input	D <sub>A</sub>	[kW]	15,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,31
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	33,69
Rated power input	D <sub>B</sub>	[kW]	9,28
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,63
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	31,29
Rated power input	D <sub>C</sub>	[kW]	5,98
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,23
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	26,50
Rated power input	D <sub>D</sub>	[kW]	4,57
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,80
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0182			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,00
Annual electricity consumption	Q	[kWh]	65062
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	43,89
Rated power input	D <sub>A</sub>	[kW]	17,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,49
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	40,97
Rated power input	D <sub>B</sub>	[kW]	11,60
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,53
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	38,05
Rated power input	D <sub>C</sub>	[kW]	7,81
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,87
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	31,40
Rated power input	D <sub>D</sub>	[kW]	5,74
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,47
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0182			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,62
Annual electricity consumption	Q	[kWh]	57965
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	44,00
Rated power input	D <sub>A</sub>	[kW]	17,50
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,52
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	41,07
Rated power input	D <sub>B</sub>	[kW]	11,40
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,61
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	38,13
Rated power input	D <sub>C</sub>	[kW]	7,69
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,95
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	31,50
Rated power input	D <sub>D</sub>	[kW]	5,65
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,57
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0202			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,12
Annual electricity consumption	Q	[kWh]	71524
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	49,39
Rated power input	D <sub>A</sub>	[kW]	21,00
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,35
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	46,11
Rated power input	D <sub>B</sub>	[kW]	13,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,55
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	42,81
Rated power input	D <sub>C</sub>	[kW]	8,69
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,93
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	35,80
Rated power input	D <sub>D</sub>	[kW]	6,48
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,53
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0202			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,68
Annual electricity consumption	Q	[kWh]	64617
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	$P_A$	[kW]	49,50
Rated power input	$D_A$	[kW]	20,90
Rated energy efficiency ratio	$EER_{DC,A}$		2,37
Parameters at rating point B			
Rated refrigeration capacity	$P_B$	[kW]	46,20
Rated power input	$D_B$	[kW]	12,90
Declared energy efficiency ratio	$EER_{DC,B}$		3,58
Parameters at rating point C			
Rated refrigeration capacity	$P_C$	[kW]	42,90
Rated power input	$D_C$	[kW]	8,57
Declared energy efficiency ratio	$EER_{DC,C}$		5,01
Parameters at rating point D			
Rated refrigeration capacity	$P_D$	[kW]	35,80
Rated power input	$D_D$	[kW]	6,46
Declared energy efficiency ratio	$EER_{DC,D}$		5,55
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	$C_{DC}$		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0252			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		4,97
Annual electricity consumption	Q	[kWh]	83164
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	55,76
Rated power input	D <sub>A</sub>	[kW]	23,80
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,34
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	52,08
Rated power input	D <sub>B</sub>	[kW]	15,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,47
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	48,36
Rated power input	D <sub>C</sub>	[kW]	10,30
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,70
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	40,30
Rated power input	D <sub>D</sub>	[kW]	7,64
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,27
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy



NRCS-FC-Z /SL 0252			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,45
Annual electricity consumption	Q	[kWh]	75945
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	55,89
Rated power input	D <sub>A</sub>	[kW]	23,70
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,36
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	52,17
Rated power input	D <sub>B</sub>	[kW]	14,90
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,50
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	48,45
Rated power input	D <sub>C</sub>	[kW]	10,10
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,79
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	40,20
Rated power input	D <sub>D</sub>	[kW]	7,65
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,26
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0302			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,24
Annual electricity consumption	Q	[kWh]	104302
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	73,69
Rated power input	D <sub>A</sub>	[kW]	30,70
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,40
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	68,79
Rated power input	D <sub>B</sub>	[kW]	19,20
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,58
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	63,87
Rated power input	D <sub>C</sub>	[kW]	13,20
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,84
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	52,40
Rated power input	D <sub>D</sub>	[kW]	9,74
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,38
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0302			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,64
Annual electricity consumption	Q	[kWh]	96895
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	73,80
Rated power input	D <sub>A</sub>	[kW]	30,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,41
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	68,88
Rated power input	D <sub>B</sub>	[kW]	19,10
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,61
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	63,96
Rated power input	D <sub>C</sub>	[kW]	13,10
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,89
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	52,40
Rated power input	D <sub>D</sub>	[kW]	9,73
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,38
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0352			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,09
Annual electricity consumption	Q	[kWh]	125141
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	85,90
Rated power input	D <sub>A</sub>	[kW]	34,90
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,46
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	80,17
Rated power input	D <sub>B</sub>	[kW]	22,80
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,52
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	74,45
Rated power input	D <sub>C</sub>	[kW]	16,00
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,65
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	53,70
Rated power input	D <sub>D</sub>	[kW]	10,20
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,28
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0352			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,55
Annual electricity consumption	Q	[kWh]	114982
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	86,09
Rated power input	D <sub>A</sub>	[kW]	34,90
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,47
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	80,36
Rated power input	D <sub>B</sub>	[kW]	22,60
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,56
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	74,62
Rated power input	D <sub>C</sub>	[kW]	15,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,72
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	53,70
Rated power input	D <sub>D</sub>	[kW]	10,20
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,27
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0412			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,36
Annual electricity consumption	Q	[kWh]	135642
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	98,06
Rated power input	D <sub>A</sub>	[kW]	38,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,54
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	91,56
Rated power input	D <sub>B</sub>	[kW]	24,90
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,68
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	85,02
Rated power input	D <sub>C</sub>	[kW]	17,00
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,00
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	71,40
Rated power input	D <sub>D</sub>	[kW]	12,90
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,51
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0412			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,82
Annual electricity consumption	Q	[kWh]	125117
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	98,25
Rated power input	D <sub>A</sub>	[kW]	38,40
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,56
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	91,75
Rated power input	D <sub>B</sub>	[kW]	24,70
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,71
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	85,19
Rated power input	D <sub>C</sub>	[kW]	16,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,07
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	71,40
Rated power input	D <sub>D</sub>	[kW]	12,90
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,53
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0452			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,28
Annual electricity consumption	Q	[kWh]	150593
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	107,29
Rated power input	D <sub>A</sub>	[kW]	44,50
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,41
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	100,15
Rated power input	D <sub>B</sub>	[kW]	28,50
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,51
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	92,99
Rated power input	D <sub>C</sub>	[kW]	19,30
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,82
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	72,20
Rated power input	D <sub>D</sub>	[kW]	13,00
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,55
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy



NRCS-FC-Z /SL 0452			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,69
Annual electricity consumption	Q	[kWh]	140014
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	107,46
Rated power input	D <sub>A</sub>	[kW]	44,40
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,42
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	100,33
Rated power input	D <sub>B</sub>	[kW]	28,30
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,54
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	93,17
Rated power input	D <sub>C</sub>	[kW]	19,10
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,88
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	72,20
Rated power input	D <sub>D</sub>	[kW]	13,00
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,54
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0512			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,21
Annual electricity consumption	Q	[kWh]	171818
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	120,80
Rated power input	D <sub>A</sub>	[kW]	49,30
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,45
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	112,75
Rated power input	D <sub>B</sub>	[kW]	31,80
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,54
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	104,69
Rated power input	D <sub>C</sub>	[kW]	21,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,80
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	87,90
Rated power input	D <sub>D</sub>	[kW]	16,30
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,41
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0512			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,55
Annual electricity consumption	Q	[kWh]	161412
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	121,00
Rated power input	D <sub>A</sub>	[kW]	49,20
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,46
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	112,93
Rated power input	D <sub>B</sub>	[kW]	31,60
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,57
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	104,87
Rated power input	D <sub>C</sub>	[kW]	21,60
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,86
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	87,90
Rated power input	D <sub>D</sub>	[kW]	16,30
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,37
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0552			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,30
Annual electricity consumption	Q	[kWh]	191083
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	136,77
Rated power input	D <sub>A</sub>	[kW]	57,20
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,39
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	127,68
Rated power input	D <sub>B</sub>	[kW]	36,70
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,48
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	118,56
Rated power input	D <sub>C</sub>	[kW]	24,90
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,76
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	89,80
Rated power input	D <sub>D</sub>	[kW]	16,10
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,57
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0552			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,61
Annual electricity consumption	Q	[kWh]	180815
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	136,90
Rated power input	D <sub>A</sub>	[kW]	57,00
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,40
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	127,77
Rated power input	D <sub>B</sub>	[kW]	36,60
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,49
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	118,65
Rated power input	D <sub>C</sub>	[kW]	24,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,78
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	89,70
Rated power input	D <sub>D</sub>	[kW]	16,20
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,52
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0604			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,88
Annual electricity consumption	Q	[kWh]	183285
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	145,50
Rated power input	D <sub>A</sub>	[kW]	62,20
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,34
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	135,80
Rated power input	D <sub>B</sub>	[kW]	35,20
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,86
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	126,10
Rated power input	D <sub>C</sub>	[kW]	24,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,08
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	116,40
Rated power input	D <sub>D</sub>	[kW]	13,89
Declared energy efficiency ratio	EER <sub>DC,D</sub>		8,38
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0604			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,42
Annual electricity consumption	Q	[kWh]	198459
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	145,30
Rated power input	D <sub>A</sub>	[kW]	62,40
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,33
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	135,61
Rated power input	D <sub>B</sub>	[kW]	35,40
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,83
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	125,93
Rated power input	D <sub>C</sub>	[kW]	25,00
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,04
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	116,24
Rated power input	D <sub>D</sub>	[kW]	16,88
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,88
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0612			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,22
Annual electricity consumption	Q	[kWh]	223673
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	157,60
Rated power input	D <sub>A</sub>	[kW]	63,50
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,48
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	147,09
Rated power input	D <sub>B</sub>	[kW]	41,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,59
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	136,59
Rated power input	D <sub>C</sub>	[kW]	27,90
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,90
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	114,80
Rated power input	D <sub>D</sub>	[kW]	20,90
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,50
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy



NRCS-FC-Z /SL 0612			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,55
Annual electricity consumption	Q	[kWh]	210696
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	157,70
Rated power input	D <sub>A</sub>	[kW]	63,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,48
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	147,19
Rated power input	D <sub>B</sub>	[kW]	40,90
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,60
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	136,67
Rated power input	D <sub>C</sub>	[kW]	27,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,92
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	114,60
Rated power input	D <sub>D</sub>	[kW]	21,10
Declared energy efficiency ratio	EER <sub>DC,D</sub>		5,42
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0704			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,67
Annual electricity consumption	Q	[kWh]	220682
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	168,90
Rated power input	D <sub>A</sub>	[kW]	71,30
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,37
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	157,64
Rated power input	D <sub>B</sub>	[kW]	42,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,75
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	146,38
Rated power input	D <sub>C</sub>	[kW]	29,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,91
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	135,12
Rated power input	D <sub>D</sub>	[kW]	16,89
Declared energy efficiency ratio	EER <sub>DC,D</sub>		8,00
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0704			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,30
Annual electricity consumption	Q	[kWh]	235630
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	168,70
Rated power input	D <sub>A</sub>	[kW]	71,50
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,36
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	157,45
Rated power input	D <sub>B</sub>	[kW]	42,30
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,72
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	146,21
Rated power input	D <sub>C</sub>	[kW]	30,00
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,87
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	134,96
Rated power input	D <sub>D</sub>	[kW]	19,82
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,81
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0804			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,59
Annual electricity consumption	Q	[kWh]	250069
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	188,69
Rated power input	D <sub>A</sub>	[kW]	80,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,34
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	176,12
Rated power input	D <sub>B</sub>	[kW]	47,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,75
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	163,54
Rated power input	D <sub>C</sub>	[kW]	32,80
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,98
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	150,96
Rated power input	D <sub>D</sub>	[kW]	19,87
Declared energy efficiency ratio	EER <sub>DC,D</sub>		7,60
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0804			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,23
Annual electricity consumption	Q	[kWh]	267191
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	188,50
Rated power input	D <sub>A</sub>	[kW]	80,90
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,33
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	175,93
Rated power input	D <sub>B</sub>	[kW]	47,20
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,73
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	163,37
Rated power input	D <sub>C</sub>	[kW]	33,00
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,95
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	150,80
Rated power input	D <sub>D</sub>	[kW]	23,35
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,46
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 0904			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,91
Annual electricity consumption	Q	[kWh]	267362
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	213,30
Rated power input	D <sub>A</sub>	[kW]	89,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,38
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	199,08
Rated power input	D <sub>B</sub>	[kW]	52,40
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,80
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	184,86
Rated power input	D <sub>C</sub>	[kW]	36,40
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,08
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	170,64
Rated power input	D <sub>D</sub>	[kW]	19,93
Declared energy efficiency ratio	EER <sub>DC,D</sub>		8,56
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 0904			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,47
Annual electricity consumption	Q	[kWh]	288306
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	213,00
Rated power input	D <sub>A</sub>	[kW]	89,90
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,37
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	198,80
Rated power input	D <sub>B</sub>	[kW]	52,70
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,77
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	184,60
Rated power input	D <sub>C</sub>	[kW]	36,70
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,03
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	170,40
Rated power input	D <sub>D</sub>	[kW]	24,01
Declared energy efficiency ratio	EER <sub>DC,D</sub>		7,10
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 1004			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,96
Annual electricity consumption	Q	[kWh]	299803
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	241,20
Rated power input	D <sub>A</sub>	[kW]	97,30
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,48
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	225,12
Rated power input	D <sub>B</sub>	[kW]	57,20
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,94
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	209,04
Rated power input	D <sub>C</sub>	[kW]	40,00
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,22
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	192,96
Rated power input	D <sub>D</sub>	[kW]	23,21
Declared energy efficiency ratio	EER <sub>DC,D</sub>		8,32
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy



NRCS-FC-Z /NG /SL 1004			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,57
Annual electricity consumption	Q	[kWh]	320184
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	240,90
Rated power input	D <sub>A</sub>	[kW]	97,50
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,47
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	224,84
Rated power input	D <sub>B</sub>	[kW]	57,50
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,91
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	208,78
Rated power input	D <sub>C</sub>	[kW]	40,30
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,18
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	192,72
Rated power input	D <sub>D</sub>	[kW]	27,23
Declared energy efficiency ratio	EER <sub>DC,D</sub>		7,08
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 1104			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		6,09
Annual electricity consumption	Q	[kWh]	335021
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	275,46
Rated power input	D <sub>A</sub>	[kW]	112,00
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,46
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	257,13
Rated power input	D <sub>B</sub>	[kW]	65,30
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,94
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	238,77
Rated power input	D <sub>C</sub>	[kW]	45,00
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,31
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	220,40
Rated power input	D <sub>D</sub>	[kW]	25,42
Declared energy efficiency ratio	EER <sub>DC,D</sub>		8,67
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 1104			
-			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,56
Annual electricity consumption	Q	[kWh]	366483
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	275,15
Rated power input	D <sub>A</sub>	[kW]	112,30
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,45
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	256,85
Rated power input	D <sub>B</sub>	[kW]	65,60
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,92
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	238,51
Rated power input	D <sub>C</sub>	[kW]	45,30
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,26
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	220,16
Rated power input	D <sub>D</sub>	[kW]	31,79
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,93
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 1204			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,82
Annual electricity consumption	Q	[kWh]	393114
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	308,79
Rated power input	D <sub>A</sub>	[kW]	128,70
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,40
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	288,21
Rated power input	D <sub>B</sub>	[kW]	75,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,84
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	267,63
Rated power input	D <sub>C</sub>	[kW]	52,10
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,14
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	247,04
Rated power input	D <sub>D</sub>	[kW]	30,63
Declared energy efficiency ratio	EER <sub>DC,D</sub>		8,06
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 1204			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,38
Annual electricity consumption	Q	[kWh]	425079
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	308,50
Rated power input	D <sub>A</sub>	[kW]	128,50
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,40
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	287,93
Rated power input	D <sub>B</sub>	[kW]	75,30
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,82
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	267,37
Rated power input	D <sub>C</sub>	[kW]	52,40
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,10
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	246,80
Rated power input	D <sub>D</sub>	[kW]	37,17
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,64
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 1404			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		6,10
Annual electricity consumption	Q	[kWh]	431383
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	355,06
Rated power input	D <sub>A</sub>	[kW]	142,60
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,49
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	331,43
Rated power input	D <sub>B</sub>	[kW]	84,30
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,93
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	307,75
Rated power input	D <sub>C</sub>	[kW]	58,60
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,25
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	284,08
Rated power input	D <sub>D</sub>	[kW]	32,30
Declared energy efficiency ratio	EER <sub>DC,D</sub>		8,79
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /NG /SL 1404			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,61
Annual electricity consumption	Q	[kWh]	468450
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	354,49
Rated power input	D <sub>A</sub>	[kW]	143,50
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,47
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	330,87
Rated power input	D <sub>B</sub>	[kW]	85,00
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,89
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	307,23
Rated power input	D <sub>C</sub>	[kW]	59,20
Declared energy efficiency ratio	EER <sub>DC,C</sub>		5,19
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	283,60
Rated power input	D <sub>D</sub>	[kW]	39,47
Declared energy efficiency ratio	EER <sub>DC,D</sub>		7,19
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

NRCS-FC-Z /SL 1604			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,63
Annual electricity consumption	Q	[kWh]	518106
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	393,80
Rated power input	D <sub>A</sub>	[kW]	162,70
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,42
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	367,55
Rated power input	D <sub>B</sub>	[kW]	95,80
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,84
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	341,29
Rated power input	D <sub>C</sub>	[kW]	69,50
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,91
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	315,04
Rated power input	D <sub>D</sub>	[kW]	40,59
Declared energy efficiency ratio	EER <sub>DC,D</sub>		7,76
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy



NRCS-FC-Z /NG /SL 1604			
Type of condensing	Air cooled / Water cooled		Air cooled
Refrigerant fluid(s)	Information to identify the refrigerant fluid(s) intended to be used with the condensing unit		-
Type	compressor driven vapour compression or sorption process		Compressor driven vapour compression
Operating temperature	t	[°C]	-
Seasonal energy performance ratio	SEPR		5,16
Annual electricity consumption	Q	[kWh]	564914
Parameters at full load and reference ambient temperature at rating point A			
Rated refrigeration capacity	P <sub>A</sub>	[kW]	393,20
Rated power input	D <sub>A</sub>	[kW]	163,20
Rated energy efficiency ratio	EER <sub>DC,A</sub>		2,41
Parameters at rating point B			
Rated refrigeration capacity	P <sub>B</sub>	[kW]	366,99
Rated power input	D <sub>B</sub>	[kW]	96,40
Declared energy efficiency ratio	EER <sub>DC,B</sub>		3,81
Parameters at rating point C			
Rated refrigeration capacity	P <sub>C</sub>	[kW]	340,77
Rated power input	D <sub>C</sub>	[kW]	70,20
Declared energy efficiency ratio	EER <sub>DC,C</sub>		4,85
Parameters at rating point D			
Rated refrigeration capacity	P <sub>D</sub>	[kW]	314,56
Rated power input	D <sub>D</sub>	[kW]	49,95
Declared energy efficiency ratio	EER <sub>DC,D</sub>		6,30
Other items			
Capacity control	fixed/staged/variable		Staged
Degradation coefficient for chillers	C <sub>DC</sub>		0,9
GWP of the refrigerant		[Kg CO <sub>2</sub> eq]	2088

Contact details: Mitsubishi Electric Hydronics & IT Cooling Systems S.p.A., via L. Seitz 47 - 31100 Treviso - Italy

ENGLISH	ITALIANO	FRANCAISE	DEUTSCH	ESPAÑOL
Type of condensing	Tipo di condensazione	Type de condensation	Art der Verflüssigung	Tipo de condensación
Refrigerant fluid(s)	Fluido(i) refrigerante(i)	Fluide(s) frigorigène(s)	Kältemittel	Fluido o fluidos refrigerantes
Type	Tipo	Type	Bauart	Tipo
Operating temperature	Temperatura di esercizio	Température de service	Betriebstemperatur	Temperatura de funcionamiento
Seasonal energy performance ratio	Indice di prestazione energetica stagionale	Ratio de performance énergétique saisonnier	Jahresarbeitszahl	Factor de rendimiento energético estacional
Annual electricity consumption	Consumo annuo di energia elettrica	Consommation annuelle d'électricité	Jahresstromverbrauch	Consumo anual de electricidad
<b>Parameters at full load and reference ambient temperature at rating point A</b>	<b>Parametri a pieno carico e alla temperatura ambiente al punto di valutazione A</b>	<b>Paramètres à pleine charge et à la température ambiante de référence au point d'évaluation A</b>	<b>Parameter bei Volllast und Bezugsumgebungstemperatur am Bewertungspunkt A</b>	<b>Parámetros a plena carga y a temperatura ambiente de referencia en el punto de clasificación A</b>
Rated refrigeration capacity	Capacità dichiarata di refrigerazione	Puissance de réfrigération nominale	Nennkälteleistung	Potencia nominal de refrigeración
Rated power input	Potenza nominale assorbita	Puissance absorbée nominale	Nennleistungsaufnahme	Potencia utilizada nominal
Rated energy efficiency ratio	Indice di efficienza energetica nominale	Coefficient d'efficacité énergétique nominal	Nennleistungszahl	Factor de eficiencia energética nominal
<b>Parameters at rating point B</b>	<b>Parametri al punto di valutazione B</b>	<b>Paramètres au point d'évaluation B</b>	<b>Parameter am Bewertungspunkt B</b>	<b>Parámetros en el punto de clasificación B</b>
Rated refrigeration capacity	Capacità dichiarata di refrigerazione	Puissance de réfrigération nominale	Nennkälteleistung	Potencia nominal de refrigeración
Rated power input	Potenza nominale assorbita	Puissance absorbée nominale	Nennleistungsaufnahme	Potencia utilizada nominal
Declared energy efficiency ratio	Indice di efficienza energetica dichiarato	Coefficient d'efficacité énergétique déclaré	Nennleistungszahl	Factor de eficiencia energética nominal
<b>Parameters at rating point C</b>	<b>Parametri al punto di valutazione C</b>	<b>Paramètres au point d'évaluation C</b>	<b>Parameter am Bewertungspunkt C</b>	<b>Parámetros en el punto de clasificación C</b>
Rated refrigeration capacity	Capacità dichiarata di refrigerazione	Puissance de réfrigération nominale	Nennkälteleistung	Potencia nominal de refrigeración
Rated power input	Potenza nominale assorbita	Puissance absorbée nominale	Nennleistungsaufnahme	Potencia utilizada nominal
Declared energy efficiency ratio	Indice di efficienza energetica dichiarato	Coefficient d'efficacité énergétique déclaré	Nennleistungszahl	Factor de eficiencia energética nominal
<b>Parameters at rating point D</b>	<b>Parametri al punto di valutazione D</b>	<b>Paramètres au point d'évaluation D</b>	<b>Parameter am Bewertungspunkt D</b>	<b>Parámetros en el punto de clasificación D</b>
Rated refrigeration capacity	Capacità dichiarata di refrigerazione	Puissance de réfrigération nominale	Nennkälteleistung	Potencia nominal de refrigeración
Rated power input	Potenza nominale assorbita	Puissance absorbée nominale	Nennleistungsaufnahme	Potencia utilizada nominal
Declared energy efficiency ratio	Indice di efficienza energetica dichiarato	Coefficient d'efficacité énergétique déclaré	Nennleistungszahl	Factor de eficiencia energética nominal
<b>Other items</b>	<b>Altri elementi</b>	<b>Autres caractéristiques</b>	<b>Sonstige Produktdaten</b>	<b>Otros elementos</b>
Capacity control	Dispositivo di controllo della capacità	Régulation de la puissance	Leistungsregelung	Control de la potencia
Degradation coefficient for chillers	Coefficiente di degradazione per i refrigeratori	Coefficient de dégradation pour les refroidisseurs	Minderungsfaktor von Kühlern	Coefficiente de degradación de las enfriadoras
<b>Declared energy efficiency ratio or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures Tj</b>	<b>Indice di efficienza energetica dichiarato o efficienza dell'uso del gas/fattore di energia ausiliaria a carico parziale alle temperature esterne date Tj</b>	<b>Coefficient d'efficacité énergétique déclaré ou rendement de la consommation de gaz/indice énergétique auxiliaire à charge partielle pour des températures extérieures données Tj</b>	<b>Angegebene Leistungszahl oder Gaswirkungsgrad/Hilfsenergiefaktor bei Teillast und bestimmten Außentemperaturen Tj</b>	<b>Factor de eficiencia energética declarado o eficiencia del uso de gas o factor de energía auxiliar para carga parcial a las temperaturas exteriores dadas Tj</b>
GWP of the refrigerant	GWP del refrigerante	PRP du fluide frigorigène	Treibhausgaspotenzial des Kältemittels	PCA del refrigerante
Notes:	Note:	Remarques:	Hinweise:	Notas:
The parameters are declared for application at medium temperature, except in the case of low temperature heat pumps. For low temperature heat pumps, the parameters are declared for application at low temperature.	I parametri sono dichiarati per l'applicazione a temperatura media, tranne per le pompe di calore a bassa temperatura. Per le pompe di calore a bassa temperatura, i parametri sono dichiarati per l'applicazione a bassa temperatura.	Les paramètres sont déclarés pour l'application à moyenne température, excepté pour les pompes à chaleur basse température. Pour les pompes à chaleur basse température, les paramètres sont déclarés pour l'application à basse température.	Die Parameter sind für eine Mitteltemperaturanwendung anzugeben, außer für Niedertemperatur-Wärmepumpen. Für Niedertemperatur-Wärmepumpen sind die Parameter für eine Niedertemperaturanwendung anzugeben.	Los parámetros se declararán para aplicaciones de media temperatura, excepto si se trata de bombas de calor de baja temperatura. En el caso de las bombas de calor de baja temperatura, los parámetros se declararán para aplicaciones de baja temperatura.
Unit in standard configuration/execution, without optional accessories.	Unità in configurazione ed esecuzione standard, priva di accessori opzionali.	Unité en configuration et exécution standard, sans accessoires optionnels.	Gerät mit Standard-Konfiguration und -Ausführung, ohne wunschweises Zubehör.	Unidad en configuración y ejecución estándar, sin accesorios opcionales.



**for a greener tomorrow**

Eco Changes is the Mitsubishi Electric Group's environmental statement, and expresses the Group's stance on environmental management. Through a wide range of businesses, we are helping contribute to the realization of a sustainable society.



## **MITSUBISHI ELECTRIC HYDRONICS & IT COOLING SYSTEMS S.p.A.**

Head Office: Via Roma 5 - 27010 Valle Salimbene (PV) - Italy

Tel +39 (0) 382 433 811 - Fax +39 (0) 382 587 148

[www.rcitcooling.com](http://www.rcitcooling.com)

[www.melcohit.com](http://www.melcohit.com)